



LISTING INFORMATION OF
Rav-Bariach 90 Minute Model 414 Fire Door and Frame

SPEC ID: 43115

Rav-Bariach Industries Ltd
31 Haofe

Ashkelon,
Israel

This report is for the exclusive use of Intertek's Client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this report. Only the Client is authorized to permit copying or distribution of this report and then only in its entirety. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test results in this report are relevant only to the sample tested. This report by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.

Rav-Bariach 90 Minute Model 414 Fire Door and Frame

Product Description

Single swing hollow metal fire door with metal fire door frame, hinges and mortise lockset hardware for installation in up to 90 Minute locations in stud and gypsum walls with reinforced openings per manufacturer's installation instructions, or in masonry or concrete walls.

Single Nominal Size: 3'4" x 8'-0"

Standard Pairs: Not Allowed

Double Egress Pairs: Not Allowed

Minimum Door Thickness: 2 1/4"

Attribute	Value
Criteria	NFPA 252 (2012)
Criteria	CAN / ULC S104 (2015)
Criteria	UL 10(c) 2016
Criteria	NFPA 252 (2017)
CSI Code	08 11 00 Metal Doors and Frames
Fire Resistance	90 Min PP Category D Door/Frame Assemblies
Intertek Services	Certification
Listed or Inspected	LISTED
Listing Section	CATEGORY D - DOOR/FRAME ASSEMBLIES
Report Number	G103197789, G103324416
Spec ID	43115
Swing	Single Swing
Test Original Issue Date	November 28, 2017